



Product Service

Attestation of Compliance

No. E8N 11 02 60192 007

Holder of Certificate: Gulf Security Technology Co., Ltd.No. 80, Changjiang East Road, QETDZ
066004 Qinhuangdao, Hebei
PEOPLE'S REPUBLIC OF CHINA**Name of Object:** Fire alarm devices
Interposing Relay Module**Model(s):** C-9302**Description of Object:**Operating voltage: 24VDC
Operation current: 20mA
Protection class: III**Tested according to:** EN 61000-6-3:2007
EN 50130-4/A2:2003

This Attestation of Compliance is issued according to the Directive 2004/108/EC relating to electromagnetic compatibility on a voluntary basis. It confirms that the listed apparatus complies with all essential requirements of the EMC directive and applies only to the sample and its technical documentation submitted to TÜV SÜD Product Service GmbH for testing and certification. See also notes overleaf.

Test report no.: BJ8001030301**Date,** 2011-02-18

(Jing Zhang)



After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 1