



Product Service

Attestation of Compliance

No. E8N 10 10 60192 005

Holder of Certificate: Gulf Security Technology Co., Ltd.No. 80, Changjiang East Road, QETDZ
066004 Qinhuangdao, Hebei
PEOPLE'S REPUBLIC OF CHINA**Name of Object:** Fire alarm devices
Conventional Fire Alarm Control Panel**Model(s):** GST116A, GST108A, GST104A, GST102A**Description of Object:**Rated voltage: 220/230 V, 50/60 Hz
Rated current: 0.35 A
Protection class: I**Tested according to:**EN 50130-4/A2:2003
EN 61000-6-3:2007
EN 61000-3-2:2006
EN 61000-3-3:2008

This Attestation of Compliance is issued according to the Directive 2004/108/EC relating to electromagnetic compatibility on a voluntary basis. It confirms that the listed apparatus complies with all essential requirements of the EMC directive and applies only to the sample and its technical documentation submitted to TÜV SÜD Product Service GmbH for testing and certification. See also notes overleaf.

Test report no.: BJ8001018001**Date,** 2010-10-11

(Jing Zhang)



After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 1