



China

Confirmation of Conformity

Reference No. DB 11 10 60192 004

Holder: **Gulf Security Technology Co., Ltd.**

No. 80, Changjiang East Road, QETDZ
066004, Qinhuangdao, Hebei
PEOPLE'S REPUBLIC OF CHINA

Product: **Fire alarm devices
(Intelligent Fire Alarm Control Panel)**

Model(s): **GST200-2**

Parameters:	Rated input voltage:	220/230VAC
	Rated input frequency:	50/60Hz
	Max. Rated input current:	0.5 A
	Battery supply voltage:	24VDC
	Battery supply current:	2.82A
	Protection class:	I
	Degree of protection:	IP20
	Operation:	Continuous

Tested IEC 61010-1:2010
EN 61010-1:2010

according to:

This confirmation of conformity confirms the compliance with the standards listed above on a voluntary basis. It refers only to the sample submitted to TÜV SÜD and does not certify the quality or safety of the serial products. This confirmation implies neither assessment to the production of the product, nor the conformity with national regulations. It does not permit the use of TÜV SÜD mark of conformity.

Test report no.: BJ4001029901

Date, 2011-10-14