



China

Confirmation of Conformity

Reference No. DB 14 03 60192 005

Holder: **Gulf Security Technology Co., Ltd.**
No. 80, Changjiang East Road, QETDZ
066004 Qinhuangdao, Hebei
PEOPLE'S REPUBLIC OF CHINA

Product: **Fire alarm devices**
Intelligent Fire Alarm Control Panel

Model(s): **GST200-2, GST200-2/1**
GST200-2/1PT, GST200-2/1HU

Parameters:

Rated input voltage:	220/230VAC
Rated input frequency:	50/60Hz
Max. rated input current:	0.5A
Battery supply voltage:	24VDC
Battery supply current:	2.82A
Protection class:	I
Degree of protection:	IP20
Operation:	Continuous

Tested according to: IEC 61010-1:2010
EN 61010-1:2010

This confirmation of conformity confirms the compliance with the standards listed above on a voluntary basis. It refers only to the sample submitted to TÜV SÜD and does not certify the quality or safety of the serial products. This confirmation implies neither assessment to the production of the product, nor the conformity with national regulations. It does not permit the use of TÜV SÜD mark of conformity.

Test report no.: BJ4001029902

Date, 2014-04-11

A handwritten signature in black ink, appearing to be 'Jin' or similar, written over the test report number.