

Certificate of Product Approval

Certificate Number: 548e

Issue: 14

Gulf Security Technology Co., Ltd.

No 80 Changjiang East Road
QETDZ
Qinhuangdao, Hebei Province
066004
China



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Audible Warning Devices

C-9403

I-9403

I-9406

C-9404

I-9404

DI-9405

DI-9406

(refer to Appendix for details)

Standards

EN 54-3:2001 + A1:2002 + A2:2006

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for LPCB

S Patrick

Verifier

13 August 2014

Date of Issue

21 June 2006

Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre

Appendix to Certificate No: 548e Gulf Security Technology Co., Ltd.

Issue: 14

Certified Product	Description	LPCB Ref.No.
C-9403	Conventional Sounder Strobe (Shallow Base and C-94DB Base) Notes: 1. Meets the requirements of EN 54-3: 2001 at the following tones: Tone 01 2800Hz 0.34s off / 0.4s on Tone 02 2400Hz – 2900Hz @3Hz 2. The strobe function is not in the scope of the approval.	548e/01
I-9403	Intelligent Sounder Strobe (Shallow Base and C-94DB Base) Notes: 1. Meets the requirements of EN 54-3: 2001 at the following tones: Tone 14 2400Hz-2900Hz @ 3Hz Tone 16 500Hz-1200Hz, 3.75s on / 0.25s off Pre Alarm 800Hz, 1s on / 1s off 2. Approved in both normal and power saving mode 3. The strobe function is not in the scope of the approval 4. Approved with single address and dual address (pre-alarm and main alarm)	548e/02
I-9406	Analogue Addressable Indoor Sounder Beacon Base (I-9102, I-9103 Detectors and DZ-03 Base) Notes: 1. Meets the requirements of EN 54-3: 2001 at the following tones: Tone 14 2400Hz-2900Hz @ 3Hz Tone 16 500Hz-1200Hz, 3.75s on / 0.25s off 2. The beacon function is not in the scope of this approval 3. Approved with P-9907 cover plate 4. Approved with I-9103 heat detector and I-9102 smoke detector	548e/03
C-9404	Conventional Type A Sounder (Shallow Base, C-94DB Deep Base) Note: 1. Meets the requirements of EN 54-3: 2001 at the following tones: Tone 01 2800Hz 0.34s off / 0.4s on Tone 02 2400Hz – 2900Hz @3Hz	548e/04

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

S Patrick
Verifier

13 August 2014
Date of Issue

21 June 2006
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre

Appendix to Certificate No: 548e Gulf Security Technology Co., Ltd.

Issue: 14

Certified Product	Description	LPCB Ref.No.
I-9404	Intelligent Type A Sounder (Shallow Base, C-94DB Deep Base) Note: 1. Meets the requirements of EN 54-3: 2001 at the following tones: Tone 14 2400Hz-2900Hz @ 3Hz Tone 16 500Hz-1200Hz, 3.75s on / 0.25s off Pre Alarm 800Hz, 1s on / 1s off	548e/05
DI-9405	Analogue Addressable Type A Sounder Base (DB-01) Notes: 1. Meets the requirements of EN 54-3: 2001 at the following tones: Tone 14 2400Hz-2900Hz @ 3Hz Tone 16 500Hz-1200Hz, 3.75s on / 0.25s off 2. Approved with DI-9103 heat detector and DI-9102 smoke detector	548e/06
DI-9406	Analogue Addressable Type A Flashing Sounder Beacon Base (DB-01 base) Notes: 1. Meets the requirements of EN 54-3: 2001 at the following tones: Tone 14 2400Hz-2900Hz @ 3Hz Tone 16 500Hz-1200Hz, 3.75s on / 0.25s off 2. Approved with DI-9103 heat detector and DI-9102 smoke detector 3. The visual alarm function is not in the scope of this approval	548e/07

Products Extras

Bases:

DZ-03	Standard Base
Shallow Base	Standard Base
C-94DB	Deep Base
DB-01	Mounting Base

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

S Patrick
Verifier

13 August 2014
Date of Issue

21 June 2006
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com




Appendix to Certificate No: 548e Gulf Security Technology Co., Ltd.

Issue: 14

Alternative Model Numbers and Labelling

LPCB Ref No.	Model No.	Model No./Label	Cross-listed company	Cross-Listed Co Cert./ Ref No.
548e/01	C-9403	FX9403	Emirates Fire Protections Equip. Factory. TR. Section	548e-(cl-3)
548e/01	C-9403	S-C481	SHIELD FIRE, SAFETY AND SECURITY LTD	548e-(cl-4)
548e/01	C-9403	AVD-C403	Multron Systems Pte Ltd	548e-(cl-6)
548e/02	I-9403	FX9403I	Emirates Fire Protections Equip. Factory. TR. Section	548e-(cl-3)
548e/02	I-9403	S-A491	SHIELD FIRE, SAFETY AND SECURITY LTD	548e-(cl-4)
548e/02	I-9403	AVD-A403	Multron Systems Pte Ltd	548e-(cl-6)
548e/03	I-9406	FX9406I	Emirates Fire Protections Equip. Factory. TR. Section	548e-(cl-3)
548e/03	I-9406	S-A496	SHIELD FIRE, SAFETY AND SECURITY LTD	548e-(cl-4)
548e/04	C-9404	FX9404	Emirates Fire Protections Equip. Factory. TR. Section	548e-(cl-3)
548e/04	C-9404	S-C480	SHIELD FIRE, SAFETY AND SECURITY LTD	548e-(cl-4)
548e/05	I-9404	FX9404I	Emirates Fire Protections Equip. Factory. TR. Section	548e-(cl-3)
548e/05	I-9404	S-A490	SHIELD FIRE, SAFETY AND SECURITY LTD	548e-(cl-4)

Bases

548	C-94DB	C-94DB	Multron Systems Pte Ltd	548
-----	--------	--------	-------------------------	-----

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

S Patrick
Verifier

13 August 2014
Date of Issue

21 June 2006
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre

Appendix to Certificate No: 548e Gulf Security Technology Co., Ltd.

Issue: 14

548	Shallow base	Shallow base	Multron Systems Pte Ltd	548
548	DZ-03	DZ-03	SHIELD FIRE, SAFETY AND SECURITY LTD	548
548	Shallow base	Shallow base	SHIELD FIRE, SAFETY AND SECURITY LTD	548
548	C-94DB	S-49DB	SHIELD FIRE, SAFETY AND SECURITY LTD	548
548	C-94DB	FX94DB	Emirates Fire Protections Equip. Factory. TR. Section	548
548	DZ-03	DZ-03	Emirates Fire Protections Equip. Factory. TR. Section	548
548	Shallow base	Shallow base	Emirates Fire Protections Equip. Factory. TR. Section	548

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

S Patrick
Verifier

13 August 2014
Date of Issue

21 June 2006
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com


