

Certificate of Product Approval

Certificate Number: 548p

Issue: 19

Gulf Security Technology Co., Ltd

No 80 Changjiang East Road
QETDZ
Qinhuangdao, Hebei Province
066004
China



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Control and indicating equipment

GST200-2, GST-IFP8, GST102A
GST104A, GST108A, GST116A
GST200N-2, GST200-2/1, GST200-2/1PT
GST200-2/1HU, GST200N-1

(refer to Appendix for details)

Standards

EN 54-2: 1997 + A1: 2006
EN 54-4: 1997 + A1: 2002 + A2: 2006

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.


Signed for LPCB

E Mattie-Suleiman
Verifier

19 October 2017
Date of Issue

08 May 2009
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: enquiries@breglobal.com



Appendix to Certificate No: 548p Gulf Security Technology Co., Ltd

Issue: 19

Certified Product	Description	LPCB Ref.No.
GST200-2	<p>Intelligent 2 Loop, 30 Zone Analogue Addressable Control and Indicating Equipment</p> <p>Incorporating the following units: MB-220/ F7.820.826 Main board SB-220/ F7.820.827 Switch board TB-220/ F7.820.828 Loop interface board PS-220/ F7.820.829b Power supply unit ZP-220/ F7.820.312d Zone indication and intervention board LC200/ F7.820.1125 Loop board</p> <p>Incorporating as optional modular units: P-9930/ F7.820.913a RS-232 board for configuration P-9901A Printer module kit</p> <p>Certified with the following options with requirements from EN54 part 2: 7.8 Output to Fire Alarm Devices 7.10.1 Output to automatic Fire Protection Equipment Type A 7.11 Delays to outputs 8.3 Fault signals from points 9.5 Disablement of addressable points</p>	548p/01
GST-IFP8	<p>Intelligent 8 Loop, 140 Zone Analogue Addressable Control and Indicating Equipment</p> <p>Incorporating the following units: SB-800 Indication board LCIFP8 Loop board PB-800 Power board</p>	548p/02

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.


Signed for LPCB

E Mattie-Suleiman
Verifier

19 October 2017
Date of Issue

08 May 2009
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
 T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre

Appendix to Certificate No: 548p Gulf Security Technology Co., Ltd

Issue: 19

Certified Product	Description	LPCB Ref.No.
ZP-800	ZCP board	
KB-800	Keypad board	
MB-800	Main board	
MO-800	Mother board	
PS-800	Switch Mode Power Supply SP-320-27	
Incorporating as optional modular units:		
P-9935	USB communication board	
P-9935Modbus	RS232 ModBus Communication Card	
P-9945RP	Repeater Card	
P-9945A	Class A RS485 Network Card	
P-9965	Class B CAN Network Card	
P-9965A	Class A CAN Network Card	
P-9904	Printer Interface Card	
Optional language variants;		
GST-IFP8-PT	Portuguese language variant	
GST-IFP8-HU	Hungarian language variant	
GST-IFP8-FR	French language variant	
GST-IFP8-IT	Italian language variant	
GST-IFP8-SP	Spanish language variant	
GST-IFP8-TK	Turkish language variant	
Certified with the following options with requirements from EN54 Part 2:		
7.8 Output to fire alarm devices		
7.9.1 Output to fire routing equipment		
7.9.2 Alarm confirmation input from fire routing equipment		

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.


Signed for LPCB

E Mattie-Suleiman
Verifier

19 October 2017
Date of Issue

08 May 2009
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: enquiries@breglobal.com



Appendix to Certificate No: 548p Gulf Security Technology Co., Ltd

Issue: 19

Certified Product	Description	LPCB Ref.No.
	7.10.1 Output type A 7.10.2 Output type B 7.11 Delays to outputs 7.12.1 Dependencies on more than one alarm signal - Type A 7.12.2 Dependencies on more than one alarm signal - Type B 7.13 Alarm counter 8.3 Fault signals from points 9.5 Disablement of each address point 10 Test condition Notes: 1. Scope of approval does not include the operation of the network functionality 2. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN54-13	
GST102A	2 Zone Conventional Control and Indicating Equipment Incorporating the following modules: FC-102A/ F7.843.399 Membrane CB-102A/ F2.908.1719 Control board with integrated PSE DB-102A/ F2.908.1722 Display board Optional modules: GST102A-HK Traditional Chinese text variant CF-102A/ F7.843.421 Membrane Certified with the following options with requirements from EN54 Part 2: 7.8 Output to fire alarm devices	548p/03

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.


Signed for LPCB

E Mattie-Suleiman
Verifier

19 October 2017
Date of Issue

08 May 2009
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre

Appendix to Certificate No: 548p Gulf Security Technology Co., Ltd

Issue: 19

Certified Product	Description	LPCB Ref.No.
	7.9.1 Output to fire routing equipment 7.11 Delays to outputs 10 Test condition	
GST104A	4 Zone Conventional Control and Indicating Equipment Incorporating the following modules: FC-104A/ F7.843.400 Membrane CB-104A/ F2.908.1718 Control board with integrated PSE DB-104A/ F2.908.1721 Display board Optional modules: GST104A-HK Traditional Chinese text variant CF-104A/ F7.843.422 Membrane Certified with the following options with requirements from EN54 Part 2: 7.8 Output to fire alarm devices 7.9.1 Output to fire routing equipment 7.11 Delays to outputs 10 Test condition	548p/04
GST108A	8 Zone Conventional Control and Indicating Equipment Incorporating the following modules: FC-108A/ F7.843.401 Membrane CB-108A/ F2.908.1675 Control board with integrated PSE DB-108A/ F2.908.1720 Display board	548p/05

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.


Signed for LPCB

E Mattie-Suleiman
Verifier

19 October 2017
Date of Issue

08 May 2009
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre

Appendix to Certificate No: 548p Gulf Security Technology Co., Ltd

Issue: 19

Certified Product	Description	LPCB Ref.No.
	<p>Optional modules:</p> <p>GST108A-HK Traditional Chinese text variant</p> <p>CF-108A/ F7.843.423 Membrane</p> <p>Certified with the following options with requirements from EN54 Part 2:</p> <p>7.8 Output to fire alarm devices</p> <p>7.9.1 Output to fire routing equipment</p> <p>7.11 Delays to outputs</p> <p>10 Test condition</p>	
GST116A	<p>16 Zone Conventional Control and Indicating Equipment</p> <p>Incorporating the following modules:</p> <p>FC-116A/ F7.843.402 Membrane</p> <p>CB-116A/ F2.908.1724 Control board with integrated PSE</p> <p>DB-116A/ F2.908.1676 Display board</p> <p>XB-116A/ F7.820.1677 Expansion board</p> <p>Optional modules:</p> <p>GST116A-HK Traditional Chinese text variant</p> <p>CF-116A/ F7.843.424 Membrane</p> <p>Certified with the following options with requirements from EN54 Part 2:</p> <p>7.8 Output to fire alarm devices</p> <p>7.9.1 Output to fire routing equipment</p> <p>7.11 Delays to outputs</p> <p>10 Test condition</p>	548p/06

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.


Signed for LPCB

E Mattie-Suleiman
Verifier

19 October 2017
Date of Issue

08 May 2009
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre

Appendix to Certificate No: 548p Gulf Security Technology Co., Ltd

Issue: 19

Certified Product	Description	LPCB Ref.No.
GST200N-2	<p>Intelligent 2 Loop, 30 Zone Analogue Addressable Control and Indicating Equipment</p> <p>Incorporating the following units:</p> <p>MB-220N Main board</p> <p>PS-220N Power management board</p> <p>OX-220 Terminal board</p> <p>ZP-220 Zone indication and intervention board</p> <p>SB-220 Switch board</p> <p>TB-220N Loop interface board</p> <p>LC200 Loop board</p> <p>PDF-150-27.5 Powered SMPS 100-240V power supply</p> <p>Incorporating as optional modular units:</p> <p>P-9930 RS-232 board for configuration</p> <p>P-9901A Printer module kit</p> <p>P-9960A CAN network card loop type board</p> <p>P-9940A RS485 Class A network card</p> <p>P-9930ModBus RS232 Modbus interface card</p> <p>P-9960 CAN Class B network card</p> <p>Certified with the following options with requirements from EN54 part 2:</p> <p>7.8 Output to Fire Alarm Devices</p> <p>7.10.1 Output to automatic Fire Protection Equipment Type A</p> <p>7.11 Delays to outputs</p> <p>8.3 Fault signals from points</p> <p>9.5 Disablement of addressable points</p>	548p/07

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.


Signed for LPCB

E Mattie-Suleiman
Verifier

19 October 2017
Date of Issue

08 May 2009
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre

Appendix to Certificate No: 548p Gulf Security Technology Co., Ltd

Issue: 19

Certified Product	Description	LPCB Ref.No.
	<p>Notes:</p> <ol style="list-style-type: none"> Scope of approval does not include the operation of the network functionality This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN54-13 	
GST200-2/1	<p>Intelligent 1 Loop, 30 Zone Analogue Addressable Control and Indicating Equipment</p> <p>Incorporating the following units: MB-220/ F7.820.826 Main board SB-220/ F7.820.827 Switch board TB-220/ F7.820.828 Loop interface board PS-220/ F7.820.829b Power supply unit ZP-220/ F7.820.913a Zone indication and intervention board</p> <p>Incorporating as optional modular units: P-9930/ F7.820.913a RS-232 board for configuration P-9901A Printer module kit LC200/ F7.820.1125 Loop board (for loop expansion)</p> <p>Certified with the following options with requirements from EN54 part 2: 7.8 Output to Fire Alarm Devices 7.10.1 Output to automatic Fire Protection Equipment Type A 7.11 Delays to outputs 8.3 Fault signals from points 9.5 Disablement of addressable points</p> <p>Note: can be extended to 2 loop panel by adding LC200</p>	548p/08

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.


Signed for LPCB

E Mattie-Suleiman
Verifier

19 October 2017
Date of Issue

08 May 2009
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
 T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre

Appendix to Certificate No: 548p Gulf Security Technology Co., Ltd

Issue: 19

Certified Product	Description	LPCB Ref.No.
GST200-2/1PT	<p>Intelligent 1 Loop, 30 Zone Analogue Addressable Control and Indicating Equipment (Portuguese variant) Incorporating the following units: MB-220/ F7.820.826 Main board SB-220/ F7.820.827 Switch board TB-220/ F7.820.828 Loop interface board PS-220/ F7.820.829b Power supply unit ZP-220/ F7.820.312d Zone indication and intervention board</p> <p>Incorporating as optional modular units: P-9930/ F7.820.913a RS-232 board for configuration P-9901A Printer module kit LC200/ F7.820.1125 Loop board (for loop expansion)</p> <p>Certified with the following options with requirements from EN54 part 2: 7.8 Output to Fire Alarm Devices 7.10.1 Output to automatic Fire Protection Equipment Type A 7.11 Delays to outputs 8.3 Fault signals from points 9.5 Disablement of addressable points</p> <p>Note: Can be extended to 2-loop panel by adding LC200</p>	548p/09
GST200-2/1HU	<p>Intelligent 1 Loop, 30 Zone Analogue Addressable Control and Indicating Equipment (Hungarian Variant) Incorporating the following units: MB-220/ F7.820.826 Main board</p>	548p/10

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.


Signed for LPCB

E Mattie-Suleiman
Verifier

19 October 2017
Date of Issue

08 May 2009
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: enquiries@breglobal.com



Appendix to Certificate No: 548p Gulf Security Technology Co., Ltd

Issue: 19

Certified Product	Description	LPCB Ref.No.
	SB-220/ F7.820.827 Switch board TB-220/ F7.820.828 Loop interface board PS-220/ F7.820.829b Power supply unit ZP-220/ F7.820.312d Zone indication and intervention board Incorporating as optional modular units: P-9930/ F7.820.913a RS-232 board for configuration P-9901A Printer module kit LC200/ F7.820.1125 Loop board (for loop expansion) Certified with the following options with requirements from EN54 part 2: 7.8 Output to Fire Alarm Devices 7.10.1 Output to automatic Fire Protection Equipment Type A 7.11 Delays to outputs 8.3 Fault signals from points 9.5 Disablement of addressable points Note: Can be extended to 2-loop panel by adding LC200	
GST200N-1	Intelligent 1 Loop, 30 Zone Analogue Addressable Control and Indicating Equipment Incorporating the following units: MB-220N Main board PS-220N Power management board OX-220 Terminal board ZP-220 Zone indication and intervention board SB-220 Switch board	548p/11

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.


Signed for LPCB

E Mattie-Suleiman
Verifier

19 October 2017
Date of Issue

08 May 2009
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: enquiries@breglobal.com



Appendix to Certificate No: 548p Gulf Security Technology Co., Ltd

Issue: 19

Certified Product	Description	LPCB Ref.No.
TB-220N	Loop interface board	
PDF-150-27.5	Powered SMPS 100-240V power supply	
Incorporating as optional modular units:		
P-9930	RS-232 board for configuration	
P-9901A	Printer module kit	
P-9960A	CAN network card loop type board	
P-9940A	RS485 Class A network card	
P-9930ModBus	RS232 Modbus interface card	
P-9960	CAN Class B network card	
ZP-220-GY	Indicator Board (for use with GST200N-HK only)	
ZP-220-RY	Indicator Board (for use with GST200N-HK only)	
ZP-220-GYRY	Indicator Board (for use with GST200N-HK only)	
ZP-220-NULL	Blank Board (for use with GST200N-HK only)	
Optional language variants:		
GST200N-PT	Portuguese language variant	
GST200N-HU	Hungarian language variant	
GST200N-FR	French language variant	
GST200N-IT	Italian language variant	
GST200N-SP	Spanish language variant	
GST200N-TK	Turkish language variant	
GST200N-HK	Traditional Chinese language variant	
GST200N-RO	Romanian language variant	
Certified with the following options with requirements from EN54 part 2:		

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.


Signed for LPCB

E Mattie-Suleiman
Verifier

19 October 2017
Date of Issue

08 May 2009
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre

Appendix to Certificate No: 548p Gulf Security Technology Co., Ltd

Issue: 19

Certified Product	Description	LPCB Ref.No.
	<p>7.8 Output to Fire Alarm Devices</p> <p>7.10.1 Output to automatic Fire Protection Equipment Type A</p> <p>7.11 Delays to outputs</p> <p>8.3 Fault signals from points</p> <p>9.5 Disablement of addressable points</p> <p>Notes:</p> <ol style="list-style-type: none"> 1. Can be converted to 2 loops by adding LC200 Loop board 2. Scope of approval does not include the operation of the network functionality 3. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN54-13 	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.


Signed for LPCB

E Mattie-Suleiman
Verifier

19 October 2017
Date of Issue

08 May 2009
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre

Appendix to Certificate No: 548p Gulf Security Technology Co., Ltd

Issue: 19

Alternative Model Numbers and Labelling

LPCB Ref No.	Model No.	Model No./Label	Cross-listed company	Cross-Listed Co Cert./ Ref No.
548p/01	GST200-2	P-A2M	SHIELD FIRE, SAFETY AND SECURITY LTD	548p-(cl-2)
548p/01	GST200-2	IFP2	Multron Systems Pte Ltd	548p-(cl-3)
548p/01	GST200-2	FX200-2	FIREX Protection System Technology Ltd	548p-(cl-5)
548p/01	GST200-2	SP-200-2/2	SS Fire & Security Sdn Bhd	548p-(cl-6)
548p/02	GST-IFP8	P-A8M	SHIELD FIRE, SAFETY AND SECURITY LTD	548p-(cl-2)
548p/02	GST-IFP8	IFP8	Multron Systems Pte Ltd	548p-(cl-3)
548p/02	GST-IFP8	FX-IFP8	FIREX Protection System Technology Ltd	548p-(cl-5)
548p/02	GST-IFP8	SP-IFP8	SS Fire & Security Sdn Bhd	548p-(cl-6)
548p/03	GST102A	P-C202A	SHIELD FIRE, SAFETY AND SECURITY LTD	548p-(cl-2)
548p/03	GST102A	FX102A	FIREX Protection System Technology Ltd	548p-(cl-5)
548p/03	GST102A	SP-102A	SS Fire & Security Sdn Bhd	548p-(cl-6)
548p/04	GST104A	P-C204A	SHIELD FIRE, SAFETY AND SECURITY LTD	548p-(cl-2)
548p/04	GST104A	FX104A	FIREX Protection System Technology Ltd	548p-(cl-5)
548p/04	GST104A	SP-104A	SS Fire & Security Sdn Bhd	548p-(cl-6)
548p/05	GST108A	P-C208A	SHIELD FIRE, SAFETY AND SECURITY LTD	548p-(cl-2)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.


Signed for LPCB

E Mattie-Suleiman
Verifier

19 October 2017
Date of Issue

08 May 2009
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre

Appendix to Certificate No: 548p Gulf Security Technology Co., Ltd

Issue: 19

LPCB Ref No.	Model No.	Model No./Label	Cross-listed company	Cross-Listed Co Cert./ Ref No.
548p/05	GST108A	FX108A	FIREX Protection System Technology Ltd	548p-(cl-5)
548p/05	GST108A	SP-108A	SS Fire & Security Sdn Bhd	548p-(cl-6)
548p/06	GST116A	P-C216A	SHIELD FIRE, SAFETY AND SECURITY LTD	548p-(cl-2)
548p/06	GST116A	FX116A	FIREX Protection System Technology Ltd	548p-(cl-5)
548p/06	GST116A	SP-116A	SS Fire & Security Sdn Bhd	548p-(cl-6)
548p/07	GST200N-2	P-A300N-2	SHIELD FIRE, SAFETY AND SECURITY LTD	548p-(cl-2)
548p/07	GST200N-2	IFP2N	Multron Systems Pte Ltd	548p-(cl-3)
548p/07	GST200N-2	FX200N-2	FIREX Protection System Technology Ltd	548p-(cl-5)
548p/07	GST200N-2	SP-200N-2	SS Fire & Security Sdn Bhd	548p-(cl-6)
548p/08	GST200-2/1	P-A2M/1	SHIELD FIRE, SAFETY AND SECURITY LTD	548p-(cl-2)
548p/08	GST200-2/1	IFP2/1	Multron Systems Pte Ltd	548p-(cl-3)
548p/08	GST200-2/1	FX200-2/1	FIREX Protection System Technology Ltd	548p-(cl-5)
548p/08	GST200-2/1	SP-200-2/1	SS Fire & Security Sdn Bhd	548p-(cl-6)
548p/11	GST200N-1	P-A300N-1	SHIELD FIRE, SAFETY AND SECURITY LTD	548p-(cl-2)
548p/11	GST200N-1	IFP1N	Multron Systems Pte Ltd	548p-(cl-3)
548p/11	GST200N-1	FX200N-1	FIREX Protection System Technology Ltd	548p-(cl-5)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.


Signed for LPCB

E Mattie-Suleiman
Verifier

19 October 2017
Date of Issue

08 May 2009
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre

Appendix to Certificate No: 548p Gulf Security Technology Co., Ltd

Issue: 19

LPCB Ref No.	Model No.	Model No./Label	Cross-listed company	Cross-Listed Co Cert./ Ref No.
548p/11	GST200N-1	SP-200N-1	SS Fire & Security Sdn Bhd	548p-(cl-6)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.


Signed for LPCB

E Mattie-Suleiman
Verifier

19 October 2017
Date of Issue

08 May 2009
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre