

CERTIFICATE OF COMPLIANCE

Certificate Number 20140317-S9080
Report Reference S9080-20140312
Issue Date 2014-MARCH-17

Issued to: GULF SECURITY TECHNOLOGY CO LTD
NO 80 CHANGJIANG EAST RD, QETDZ
QINHUANGDAO
HEBEI 066004 CHINA

**This is to certify that
representative samples of**

HEAT-AUTOMATIC FIRE DETECTORS
Fire Alarm Subassembly:

USL - Heat Detector head, intelligent (addressable), Model
DI-M9103 combination 135 °F (57.2 °C) fixed
temperature and 15 °F/min (8.3 °C/min) rate of rise.


USL - Heat Detector head, conventional, Model DC-M9103
combination 135 °F (57.2 °C) fixed temperature and 15
°F/min (8.3 °C/min) rate of rise.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety: Standard for Safety for Heat Detectors for Fire Protective
Signaling Systems, ANSI/UL 521

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's
Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the
word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category
name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus

