



防 爆 合 格 证

CONFORMITY CERTIFICATE OF EXPLOSION-PROOF

证 号
Certificate No. CE21. 0157

产 品 名 称
Name of Product 手动火灾报警按钮

型 号 及 规 格
Type of Product DC-9202 (IS)

防 爆 标 志
Marking Ex ib II C T6 Gb

技 术 文 件
Technical Documents Q/GST C053.1-2011, Q/GST C053.11-2011

图 号
Drawing No. F2. 909. 1262

备 注
Note (s)

1. 额定电压：24VDC。本安参数：Ui:28VDC, Ii:100mA, Pi:651mW, Ci:0 μF, Li:0mH。
2. 产品使用环境温度：-10°C ≤ Ta ≤ +55°C。
3. 此产品必须与安装在安全区的关联设备连接，关联设备参数见使用说明书。
4. 产品外壳防护等级为 IP43。

经对上述产品图样及技术文件的审查和样品的检验,其符合以下标准

By verifying the drawings and technical documents and checking samples, the product complies with the following standards

GB 3836.1-2010 GB 3836.4-2010

发 给：
Issued to: 海湾安全技术有限公司

本证失效日期：2026-10-08

Date of Expire:

发证日期：2021-10-08

Date of Issue:

中心印章
Center seal



中心主任
Director

国家防爆产品质量检验检测中心(天津)
(石油和化学工业电气产品防爆质量监督检验中心)
National Explosion-proof Product Quality Inspection and Testing Center (Tianjin)

注: 本证仅对与批准的审查认可文件和送检样品一致的产品有效

Note: This certificate is only valid for the documents approved and for the products that are in accord with samples tested and verified.

中心地址:中国天津市丁字沽三号路 85 号

邮政编码:300131

电话/传真:022-26651066 /26689116

Center Add: No.85 No.3 Road DingZiGu Tianjin China Post code: 300131

Tel/ Fax: 022-26651066/26689116

E-mail:pcec@pcec.com.cn

<http://www.pcec.com.cn>



CONFORMITY CERTIFICATE OF EXPLOSION-PROOF

Certificate No.: CE21.0157

Name of Product: Intrinsically Safe Conventional Manual Call Point
Type of Product: DC-9202 (IS)
Marking: **Ex ib II C T6 Gb**
Technical Documents: Q/GST C053.1-2011, Q/GST C053.11-2011
Drawing No.: F2.909.1262
Note (s):
1. Rated voltage: 24VDC. Intrinsically safe parameters: $U_i: 28VDC$, $I_i: 100mA$, $P_i: 651mW$, $C_i: 0\mu F$, $L_i: 0mH$.
2. Ambient temperature: $-10^{\circ}C \leq T_a \leq +55^{\circ}C$.
3. This product must be connected to the associated apparatus which is mounted in the safe area. For the parameters of the associated apparatus see the manual.
4. IP code: IP43.

By verifying the drawings and technical documents and checking samples, the product complies with the following standards:

GB 3836.1-2010 GB 3836.4-2010

Issued to: Gulf Security Technology Co., Ltd.

Date of Expire: 2026-10-08

Date of Issue: 2021-10-08

Center seal



Director

Liu Hongguang

National Explosion-proof Product Quality Inspection and Testing Center (Tianjin)
(Superision & Test Center of Ex-products of China Petroleum & Chemical Industry)