



防爆合格证

CONFORMITY CERTIFICATE OF EXPLOSION-PROOF

证号 CE17.2192
Certificate No.

产品名称
Name of Product

火灾声警报器

型号及规格
Type of Product

DC-9404 (IS)

防爆标志
Marking

Ex ib II C T6 Gb

技术文件
Technical Documents

Q/GST C091.1-2012

图号
Drawing No.

F3.928.265

备注
Note(s)

1. 本安参数: $U_i: 28VDC$, $I_i: 93 mA$, $P_i: 0.65W$, $C_i: 0 \mu F$, $L_i: 0mH$.
2. 产品使用环境温度: $-10^{\circ}C \leq T_a \leq +55^{\circ}C$.
3. 此产品必须与安装在安全区的关联设备连接, 关联设备参数见使用说明书。
4. 产品外壳防护等级为 IP33。

经对上述产品图样及技术文件的审查和样品的检验, 其符合以下标准

By verifying the drawings and technical documents and checking samples, the product complies with the following standards

GB 3836.1-2010

GB 3836.4-2010

发给: 海湾安全技术有限公司
Issued to:

本证失效日期: 2022-07-10
Date of Expire:

发证日期: 2017-07-10
Date of Issue:

中心印章
Center seal



中心主任
Director

石油和化学工业电气产品防爆质量监督检验中心
Supervision & Test Center of Ex-products of China Petroleum & Chemical Industry

注: 本证仅对与送检样品一致的产品有效

Note: This certificate is only valid for the products that are in accord with sample(s) tested and verified.

中心地址: 中国天津市丁字沽三号路 85 号

Center Add: No.85 No.3 Road DingZiGu Tianjin China Post code: 300131

E-mail: pcec@pcec.com.cn

邮政编码: 300131

电话/传真: 022-26651066 / 26689116

Tel/ Fax: 022-26651066/26689116

http://www.pcec.com.cn



CONFORMITY CERTIFICATE OF EXPLOSION-PROOF

Certificate No.: CE17.2192

Name of Product: Intrinsically Safe Conventional Sounder

Type of Product: DC-9404(IS)

Marking: **Ex ib II C T6 Gb**

Technical Documents: Q/GST C091.1-2012

Drawing No.: F3.928.265

Note (s):

1. Intrinsic safety parameters: $U_i: 28\text{VDC}$, $I_i: 93\text{mA}$, $P_i: 0.65\text{W}$,
 $C_i: 0 \mu\text{F}$, $L_i: 0\text{mH}$.
2. Ambient temperature: $-10^\circ\text{C} \leq T_a \leq +55^\circ\text{C}$.
3. This product must be connected to the associated apparatus which is mounted in the safe area. For the parameters of the associated apparatus see the manual.
4. Degree of protection: IP33.

By verifying the drawings and technical documents and checking samples, the product complies with the following standards:

GB 3836.1-2010 GB 3836.4-2010

Issued to: Gulf Security Technology Co., Ltd.

Date of Expire: 2022-07-10

Date of Issue: 2017-07-10

Center seal



Director

Liu Hongguang

Supervision & Test Center of Ex-products of China Petroleum & Chemical Industry

Note: This certificate is only valid for the products that are in accord with sample(s) tested and verified.

Center Add: No.85 No.3 Road DingZiGu Tianjin China Post code: 300131

Tel/ Fax: 022-26651066/26689116

E-mail: pcec@pcec.com.cn

<http://www.pcec.com.cn>