

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F0612

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

GST200-2, GST200-2/1, GST200-2/1PT, GST200-2/1HU

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

Gulf Security Technology Co., Ltd.
No 80 Changjiang East Road
QETDZ
Qinhuangdao, Hebei Province
066004
China

and produced in the manufacturing plant(s):

Gulf Security Technology Co., Ltd.
No 80 Changjiang East Road
QETDZ
Qinhuangdao, Hebei Province
066004
China

Choose an item or hit spacebar.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-2: 1997 + A1: 2006 Control and indication equipment + A1: 2002 + A2: 2006 - Power supply equipment

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 15 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



E. Mattie-Suleiman, Certification Engineer

Date of First Issue: 15 October 2019

Date of Issue: 15 October 2019

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BRE Global Ireland**Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland

T: +353 (0) 18824344

E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F0612**GST200-2, GST200-2/1, GST200-2/1PT, GST200-2/1HU****GST200-2**

Intelligent 2 Loop, 30 Zone Analogue Addressable Control and Indicating Equipment

Incorporating the following units:

MB-220/ F7.820.826 Main board

SB-220/ F7-820.827 Switch board

TB-220/ F7.820.828 Loop interface board

PS-220/ F7.820.829b Power supply unit

ZP-220/ F7-820.312d Zone indication and intervention board

LC200/ F7.820.1125 Loop board

Incorporating as optional modular units:

P-9930/ F7.820.913a RS-232 board for configuration

P-9901A Printer module kit

Certified with the following options with requirements from EN 54 part 2:

7.8 Output to Fire Alarm Devices

7.10.1 Output to automatic Fire Protection Equipment Type A

7.11 Delays to outputs

8.3 Fault signals from points

9.5 Disablement of addressable points

GST200-2/1

Intelligent 1 Loop, 30 Zone Analogue Addressable Control and Indicating Equipment

Incorporating the following units:

MB-220/ F7.820.826 Main board

SB-220/ F7-820.827 Switch board

TB-220/ F7.820.828 Loop interface board



E. Mattie-Suleiman, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 15 October 2019

Date of issue: 15 October 2019

Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BRE Global Ireland**Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland

T: +353 (0) 18824344

E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F0612

PS-220/ F7.820.829b Power supply unit
ZP-220/F7.908.312d Zone indication and intervention board

Incorporating as optional modular units:

P-9930/ F7.820.913a RS-232 board for configuration
P-9901A Printer module kit
LC200/ F7-820.1125 Loop board (for loop expansion)

Certified with the following options with requirements from EN 54 part 2:

7.8 Output to Fire Alarm Devices
7.10.1 Output to automatic Fire Protection Equipment Type A
7.11 Delays to outputs
8.3 Fault signals from points
9.5 Disablement of addressable points
Note: can be extended to 2 loop panel by adding LC200

GST200-2/1PT

Intelligent 1 Loop, 30 Zone Analogue Addressable Control and Indicating Equipment (Portuguese variant)

Incorporating the following units:

MB-220/ F7-820.826 Main board
SB-220/ F7-820.827 Switch board
TB-220/ F7-820.828 Loop interface board
PS-220/ F7-820.829b Power supply unit
ZP-220/ F7.820.312d Zone indication and intervention board

Incorporating as optional modular units:

P-9930/ F7-820.913a RS-232 board for configuration
P-9901A Printer module kit
LC200/ F7-820.1125 Loop board (for loop expansion)

Certified with the following options with requirements from EN 54 part 2:

7.8 Output to Fire Alarm Devices



E. Mattie-Suleiman, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 15 October 2019

Date of issue: 15 October 2019

Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F0612

7.10.1 Output to automatic Fire Protection Equipment Type A
7.11 Delays to outputs
8.3 Fault signals from points
9.5 Disablement of addressable points
Note: can be extended to 2-loop panel by adding LC200

GST200-2/1HU

Intelligent 1 Loop, 30 Zone Analogue Addressable Control and Indicating Equipment (Hungarian variant)

Incorporating the following units:


MB-220/ F7-820.826 Main board
SB-220/ F7-820.827 Switch board
TB-220/ F7-820.828 Loop interface board
PS-220/ F7-820.829b Power supply unit
ZP-220/ F7.820.312d Zone indication and intervention board

Incorporating as optional modular units:

P-9930/ F7-820.913a RS-232 board for configuration
P-9901A Printer module kit
LC200/ F7-820.1125 Loop board (for loop expansion)

Certified with the following options with requirements from EN 54 part 2:

7.8 Output to Fire Alarm Devices
7.10.1 Output to automatic Fire Protection Equipment Type A
7.11 Delays to outputs
8.3 Fault signals from points
9.5 Disablement of addressable points
Note: can be extended to 2-loop panel by adding LC200


E. Mattie-Suleiman, Certification Engineer,
On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 15 October 2019
Date of issue: 15 October 2019
Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.