

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F0994

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

GST-IFP8 Intelligent 8 Loop, 140 Zone Analogue Addressable Control and Indicating Equipment

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of: and produced in the manufacturing plant(s):

Gulf Security Technology Co., Ltd
No. 80 Changjiang East Road
QETDZ
Qinhuangdao, Hebei Province
066004
China

Gulf Security Technology Co., Ltd
No. 80 Changjiang East Road
QETDZ
Qinhuangdao, Hebei Province
066004
China

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-2:1997 + A1:2006 - Control and indicating equipment
EN 54-4:1997 + A1:2002 + A2:2006 - Power supply equipment

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 15 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



E. Mattie-Suleiman, Certification Engineer

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 15 October 2019

Date of Issue: 15 October 2019

Issue number 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BRE Global Ireland**Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F0994**GST-IFP8 Intelligent 8 Loop, 140 Zone Analogue Addressable Control and Indicating Equipment**

Incorporating the following units:

SB-800	Indication board
LCIFP8	Loop board
PB-800	Power board
ZP-800	ZCP board
KB-800	Keypad board
MB-800	Main board
MO-800	Mother board
PS-800	Switch Mode Power Supply SP-320-27

Incorporating as optional modular units:

P-9935	USB communication board
P-9935Modbus	RS232 ModBus Communication Card
P-9945RP	Repeater Card
P-9945A	Class A RS485 Network Card
P-9965	Class B CAN Network Card
P-9965A	Class A CAN Network Card
P-9904	Printer Interface Card

Optional language variants;

GST-IFP8-PT	Portuguese language variant
GST-IFP8-HU	Hungarian language variant
GST-IFP8-FR	French language variant
GST-IFP8-IT	Italian language variant
GST-IFP8-SP	Spanish language variant
GST-IFP8-TK	Turkish language variant

Certified with the following options with requirements from EN 54 Part 2:

- 7.8 Output to fire alarm devices
- 7.9.1 Output to fire routing equipment
- 7.9.2 Alarm confirmation input from fire routing equipment
- 7.10.1 Output type A
- 7.10.2 Output type B
- 7.11 Delays to outputs



E. Mattie-Suleiman, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 15 October 2019

Date of issue: 15 October 2019

Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F0994

- 7.12.1 Dependencies on more than one alarm signal - Type A
- 7.12.2 Dependencies on more than one alarm signal - Type B
- 7.13 Alarm counter
- 8.3 Fault signals from points
- 9.5 Disablement of each address point
- 10 Test condition

Notes:

1. Scope of approval does not include the operation of the network functionality
2. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN54-13



E. Mattie-Suleiman, Certification Engineer,
On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 15 October 2019

Date of issue: 15 October 2019

Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.