

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F2359

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

I-9406 Analogue Addressable Indoor Sounder Beacon

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

and produced in the manufacturing plant(s):

Gulf Security Technology Co., Ltd
No 80 Changjiang East Road
QETDZ, Qinhuangdao
Hebei Province
066004
China

Gulf Security Technology Co., Ltd
No 80 Changjiang East Road
QETDZ, Qinhuangdao
Hebei Province
066004
China

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-3: 2001 + A1: 2002 + A2: 2006 Sounders

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 15 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



E. Mattie-Suleiman, Certification Engineer

Date of First Issue: 15 October 2019

Date of Issue: 15 October 2019

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BRE Global Ireland**Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F2359**I-9406 Analogue Addressable Indoor Sounder Beacon****Bases**

DZ-03

Ancillaries

- a) Approved with I-9103 Heat Detector
- b) Approved with I-9102 Smoke Detector
- c) Approved with P-9907 Cover Plate

Sounder Tones

Tone 14 2400Hz – 2900Hz @ 3Hz

Tone 16 500Hz – 1200Hz, 3.75s on / 0.25s off

The beacon functionality is not approved to EN 54-23



E. Mattie-Suleiman, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 15 October 2019

Date of issue: 15 October 2019

Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.