

**DECLARATION OF PERFORMANCE No. 0832-CPD-2156 REV 1.03**  
**According to Construction Products Regulation EU No. 305/2011**

**This declaration is available in the following languages:**

<b>English</b>	<b>Declaration of Performance</b>	<b>Page 2-3</b>
<b>Hungarian</b>	<b>TELJESÍTMÉNYNYILATKOZAT</b>	<b>Page 4-5</b>

## DECLARATION OF PERFORMANCE

1. Unique Product identification code:	Model(s): C-9101
2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):	Each individual product is identified with a label containing a unique batch number.
3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:	Smoke detectors – Point detectors using scattered light, transmitted light or ionization EN54-7, heat detectors-Point detectors for fire detection and fire alarm systems for buildings EN54-5
4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):	Gulf Security Technology Co., Ltd. No. 80 Changjiang East Road, QETDZ, Qinhuangdao, Hebei, China 066004
5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):	Not applicable
6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:	System 1
7. In case of the declaration of performance concerning a construction product covered by the harmonized standard:	BRE Global Limited 0832 performed type testing and the initial inspection of the manufacturing plant and of the factory production control with continuous surveillance assessment and approval of the factory production control under system 1 and issued the following EC certificates of conformity: 0832-CPD-2156
8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:	Not applicable, see item 7

### 9. Declared performance:

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in point 3 above have been determined as described in the hEN mentioned in the table below.

#### **EN 54-7 Smoke detectors — Point detectors**

Essential characteristics	Performance	Harmonized technical specification
Nominal activation conditions / Sensitivity, Response delay (response time) and Performance under fire conditions	Pass	EN 54-7:2000+A1:2002+A2:2006
Operational reliability	Pass	EN 54-7:2000+A1:2002+A2:2006
Tolerance to supply voltage	Pass	EN 54-7:2000+A1:2002+A2:2006
Durability of operational reliability and response delay: temperature resistance	Pass	EN 54-7:2000+A1:2002+A2:2006
Durability of operational reliability Vibration resistance	Pass	EN 54-7:2000+A1:2002+A2:2006
Durability of operational reliability, Humidity resistance	Pass	EN 54-7:2000+A1:2002+A2:2006
Durability of operational reliability, Corrosion resistance	Pass	EN 54-7:2000+A1:2002+A2:2006
Durability of operational reliability, electrical stability	Pass	EN 54-7:2000+A1:2002+A2:2006

#### **EN 54-5 Heat detectors — Point detectors**

Essential characteristics	Performance	Harmonized technical specification
Nominal activation conditions / Sensitivity, Response delay (response time) and Performance under fire conditions	Pass	EN 54-5:2000+A1:2002
Operational reliability	Pass	EN 54-5:2000+A1:2002
Tolerance to supply voltage	Pass	EN 54-5:2000+A1:2002
Durability of operational reliability and response delay: temperature resistance	Pass	EN 54-5:2000+A1:2002
Durability of operational reliability Vibration resistance	Pass	EN 54-5:2000+A1:2002
Durability of operational reliability, Humidity resistance	Pass	EN 54-5:2000+A1:2002
Durability of operational reliability, Corrosion resistance	Pass	EN 54-5:2000+A1:2002
Durability of operational reliability, electrical stability	Pass	EN 54-5:2000+A1:2002

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.


Signed for and on behalf of the manufacturer by:

Name: Wang Aizhong

Function: Chief Engineer



Qinhuangdao

Regulation (EU) No. 305/2011 CPR Supplementary CE marking information

Identification number of the product notified certification body: 0832
Manufacturer: Gulf Security Technology Co., Ltd. No. 80 Changjiang East Road, QETDZ, Qinhuangdao, Hebei, China 066004
Last two digits of the year in which the marking was first affixed: 13
Declaration of Performance (DoP) 0832-CPD-2156 REV 1.03
European Standard Number: EN 54-5:2000+A1:2002; EN 54-7:2000+A1:2002+A2:2006
Unique identification of product type: See the product label for the product information
Intended for use: See DoP point 3.
Essential characteristics: See DoP point 9.

## TELJESÍTMÉNYNYILATKOZAT

1. Egyedi termékazonosító kód:	Modell(ek): C-9101
2. Típus, tétel- vagy sorozatszám, illetve bármilyen más elem, amely alapján az építési termék a 11(4) cikkelynek megfelelően azonosítható:	Minden termék az egyedi tételszámot tartalmazó címke alapján azonosítható.
3. Az építési termék rendeltetésszerű használata vagy használatai a gyártó által előre meghatározott harmonizált műszaki specifikációnak megfelelően:	Füstérzékelők – Szórt fényt, továbbított fényt vagy ionizációt használó pontérzékelők EN54-7, hőérzékelők (pontérzékelők) épületek tűzérezelők és tűzriasztó rendszereihez EN54-5
4. A gyártó neve, bejegyzett neve vagy bejegyzett védjegye és kapcsolattartási címe a 11(5) cikkelyben foglaltaknak megfelelően:	Gulf Security Technology Co., Ltd. No. 80 Changjiang East Road, QETDZ, Qinhuangdao, Hebei, China 066004
5. Ahol megadható, a képviselő neve és kapcsolattartási címe, aki felhatalmazással rendelkezik a 12(2) cikkelyben megadott feladatok végrehajtására:	Nem alkalmazható
6. Az építési termék teljesítménye állandóságának kiértékelésére és ellenőrzésére szolgáló rendszer vagy rendszerek az V. mellékletben foglaltak szerint:	1. rendszer
7. Ha a teljesítménynyilatkozat egy harmonizált szabvány által érintett építési termékre vonatkozik:	BRE Global Limited 0832 típusvizsgálatot végzett, illetve elvégezte a gyártó üzem és a gyári gyártásellenőrzés kezdeti vizsgálatát folyamatos felügyeleti értékeléssel és a gyári gyártásellenőrzés jóváhagyásával az 1. rendszerben, és az alábbi EC megfelelési igazolásokat adta ki: 0832-CPD-2156
8. Ha a teljesítménynyilatkozat olyan építési termékre vonatkozik, amelyhez Európai Műszaki Értékelést adtak ki:	Nem alkalmazható, lásd a 7. elemet

### 9. Nyilatkozatban szereplő teljesítmény:

Az összes követelményt (beleértve minden alapvető jellemzőt) és a fenti 3. pontban ismertetett, rendeltetésszerű használat vagy használatok során elért teljesítményt a lenti táblázatban szereplő hEN harmonizált szabványban ismertetett módon határozták meg.

#### **EN 54-7 Füstérzékelők – Pontérzékelők**

Alapvető jellemzők	Teljesítmény	Harmonizált műszaki adatok
Névleges aktiválási feltételek / érzékenység, válaszkésleltetés (válaszidő) és teljesítmény tűz esetén	Megfelelt	EN 54-7:2000+A1:2002+A2:2006
Működési megbízhatóság	Megfelelt	EN 54-7:2000+A1:2002+A2:2006
Tápfeszültségre vonatkozó tűrés	Megfelelt	EN 54-7:2000+A1:2002+A2:2006
A működési megbízhatóság és a válaszkésleltetés tartóssága: hőmérséklet-ellenállás	Megfelelt	EN 54-7:2000+A1:2002+A2:2006
Működési megbízhatóság tartóssága, rezgésellenállás	Megfelelt	EN 54-7:2000+A1:2002+A2:2006
Működési megbízhatóság tartóssága, páratartalom-ellenállás	Megfelelt	EN 54-7:2000+A1:2002+A2:2006
Működési megbízhatóság tartóssága, korrózió-ellenállás	Megfelelt	EN 54-7:2000+A1:2002+A2:2006
Működési megbízhatóság tartóssága, elektromos stabilitás	Megfelelt	EN 54-7:2000+A1:2002+A2:2006

#### **EN 54-5 Hőérzékelők – Pontérzékelők**

Alapvető jellemzők	Teljesítmény	Harmonizált műszaki adatok
Névleges aktiválási feltételek / érzékenység, válaszkésleltetés (válaszidő) és teljesítmény tűz esetén	Megfelelt	EN 54-5:2000+A1:2002
Működési megbízhatóság	Megfelelt	EN 54-5:2000+A1:2002
Tápfeszültségre vonatkozó tűrés	Megfelelt	EN 54-5:2000+A1:2002
A működési megbízhatóság és a válaszkésleltetés tartóssága: hőmérséklet-ellenállás	Megfelelt	EN 54-5:2000+A1:2002
Működési megbízhatóság tartóssága, rezgésellenállás	Megfelelt	EN 54-5:2000+A1:2002
Működési megbízhatóság tartóssága, páratartalom-ellenállás	Megfelelt	EN 54-5:2000+A1:2002
Működési megbízhatóság tartóssága, korrózió-ellenállás	Megfelelt	EN 54-5:2000+A1:2002
Működési megbízhatóság tartóssága, elektromos stabilitás	Megfelelt	EN 54-5:2000+A1:2002

10. Az 1. és a 2. pontban azonosított termék teljesítménye megfelel a 9. pontban deklarált teljesítménynek. Ezt a teljesítménynyilatkozatot kizárólagos felelősséggel a 4. pontban azonosított gyártó adta ki.


A gyártó számára és nevében aláírta:

Név: Wang Aizhong

Beosztás: Főmérnök



Qinhuangdao

Szabályozás (EU) száma: 305/2011 CPR, kiegészítő CE jelölés adatai

A tanúsító szervezet azonosító száma, ahol a terméket bejelentették: 0832
Gyártó: Gulf Security Technology Co., Ltd. No. 80 Changjiang East Road, QETDZ, Qinhuangdao, Hebei, China 066004
Az év utolsó két számjegye, amikor a jelölést először alkalmazták: 13
Teljesítménynyilatkozat (Declaration of Performance, DoP) száma: 0832-CPD-2156 REV 1.03
Európai szabvány száma: EN 54-5:2000+A1:2002; EN 54-7:2000+A1:2002+A2:2006
A terméktípus egyedi azonosító száma: A termék adatait a termék címkéjén találja.
Rendeltetésszerű használat: Lásd a DoP 3. pontját.
Alapvető jellemzők: Lásd a DoP 9. pontját.